

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on May 25)**

Water Level of the accumulated water (at 16:00 on May 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,097 mm (4 mm decrease since 7:00 on May 25)	O.P.+ 3,204 mm (No change since 7:00 on May 25)	—
	Water level of Turbine Building	O.P.+ 3,262 mm (9 mm increase since 7:00 on May 25)	O.P.+ 3,047 mm (2 mm decrease since 7:00 on May 25)	O.P.+ 3,131 mm (2 mm decrease since 7:00 on May 25)	O.P.+ 3,131 mm (2 mm decrease since 7:00 on May 25)
	Water level of Reactor Building	O.P.+ 4,460 mm (15 mm decrease since 7:00 on May 25)	O.P.+ 3,258 mm (2 mm decrease since 7:00 on May 25)	O.P.+ 3,228 mm (5 mm decrease since 7:00 on May 25)	O.P.+ 3,144 mm (3 mm decrease since 7:00 on May 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,317 mm (Increase from initial level:5,534 mm, 127 mm increase since 7:00 on May 25) O.P.+ 2,916 mm (Increase from initial level:3,642 mm, 144 mm decrease since 7:00 on May 25) O.P.+ 4,362 mm (Water level from floor:566 mm, 4 mm increase since 7:00 on May 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:15 on May 23)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:15 on May 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:05 on May 23 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.