

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 29)**

Water Level of the accumulated water (at 7:00 on May 29)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,173 mm (4 mm decrease since 16:00 on May 28)	O.P.+ 3,178 mm (3 mm decrease since 16:00 on May 28)	—
	Water level of Turbine Building	O.P.+ 3,332 mm (12 mm increase since 16:00 on May 28)	O.P.+ 3,114 mm (3 mm decrease since 16:00 on May 28)	O.P.+ 3,106 mm (4 mm decrease since 16:00 on May 28)	O.P.+ 3,103 mm (5 mm decrease since 16:00 on May 28)
	Water level of Reactor Building	O.P.+ 4,489 mm (37 mm increase since 16:00 on May 28)	O.P.+ 3,324 mm (11 mm decrease since 16:00 on May 28)	O.P.+ 3,206 mm (3 mm decrease since 16:00 on May 28)	O.P.+ 3,118 mm (2 mm decrease since 16:00 on May 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,564 mm (Increase from initial level:5,781 mm, 9 mm increase since 16:00 on May 28) O.P.+ 2,552 mm (Increase from initial level:3,278 mm, 86 mm increase since 16:00 on May 28) O.P.+ 4,403 mm (Water level from floor:607 mm, 8 mm increase since 16:00 on May 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:34 on May 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:15 on May 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:05 on May 23 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.