

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 30)**

Water Level of the accumulated water (at 7:00 on May 30)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,165 mm (4 mm decrease since 16:00 on May 29)	O.P.+ 3,172 mm (5 mm decrease since 16:00 on May 29)	—
	Water level of Turbine Building	O.P.+ 3,351 mm (12 mm increase since 16:00 on May 29)	O.P.+ 3,106 mm (5 mm decrease since 16:00 on May 29)	O.P.+ 3,098 mm (5 mm decrease since 16:00 on May 29)	O.P.+ 3,097 mm (4 mm decrease since 16:00 on May 29)
	Water level of Reactor Building	O.P.+ 4,507 mm (29 mm increase since 16:00 on May 29)	O.P.+ 3,320 mm (1 mm decrease since 16:00 on May 29)	O.P.+ 3,199 mm (4 mm decrease since 16:00 on May 29)	O.P.+ 3,111 mm (5 mm decrease since 16:00 on May 29)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,575 mm (Increase from initial level:5,792 mm, 6 mm increase since 16:00 on May 29) O.P.+ 2,687 mm (Increase from initial level:3,413 mm, 82 mm increase since 16:00 on May 29) O.P.+ 4,417 mm (Water level from floor:621 mm, 8 mm increase since 16:00 on May 29)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:34 on May 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:15 on May 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:05 on May 23   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.