

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on May 30)**

Water Level of the accumulated water (at 16:00 on May 30)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,163 mm (2 mm decrease since 7:00 on May 30)	O.P.+ 3,172 mm (No change since 7:00 on May 30)	—
	Water level of Turbine Building	O.P.+ 3,358 mm (7 mm increase since 7:00 on May 30)	O.P.+ 3,106 mm (No change since 7:00 on May 30)	O.P.+ 3,097 mm (1 mm decrease since 7:00 on May 30)	O.P.+ 3,096 mm (1 mm decrease since 7:00 on May 30)
	Water level of Reactor Building	O.P.+ 4,496 mm (11 mm decrease since 7:00 on May 30)	O.P.+ 3,317 mm (3 mm decrease since 7:00 on May 30)	O.P.+ 3,196 mm (3 mm decrease since 7:00 on May 30)	O.P.+ 3,111 mm (No change since 7:00 on May 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,584 mm (Increase from initial level:5,801 mm, 9 mm increase since 7:00 on May 30) O.P.+ 2,745 mm (Increase from initial level:3,471 mm, 58 mm increase since 7:00 on May 30) O.P.+ 4,417 mm (Water level from floor:621 mm, No change since 7:00 on May 30)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:34 on May 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:15 on May 19)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on May 30 to 16:00 on May 30)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:05 on May 23   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.