

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 31)**

Water Level of the accumulated water (at 7:00 on May 31)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,158 mm (5 mm decrease since 16:00 on May 30)	O.P.+ 3,169 mm (3 mm decrease since 16:00 on May 30)	—
	Water level of Turbine Building	O.P.+ 3,369 mm (11 mm increase since 16:00 on May 30)	O.P.+ 3,101 mm (5 mm decrease since 16:00 on May 30)	O.P.+ 3,092 mm (5 mm decrease since 16:00 on May 30)	O.P.+ 3,092 mm (4 mm decrease since 16:00 on May 30)
	Water level of Reactor Building	O.P.+ 4,490 mm (6 mm decrease since 16:00 on May 30)	O.P.+ 3,312 mm (5 mm decrease since 16:00 on May 30)	O.P.+ 3,194 mm (2 mm decrease since 16:00 on May 30)	O.P.+ 3,107 mm (4 mm decrease since 16:00 on May 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,590 mm (Increase from initial level:5,807 mm, 6 mm increase since 16:00 on May 30) O.P.+ 2,847 mm (Increase from initial level:3,573 mm, 102 mm increase since 16:00 on May 30) O.P.+ 4,423 mm (Water level from floor:627 mm, 6 mm increase since 16:00 on May 30)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:34 on May 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:15 on May 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:36 on May 31 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	· At 8:36 AM on May 31, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for filter cleaning.				

For quick publication of the data of water level, values are provided as reference values.