

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on May 31)**

Water Level of the accumulated water (at 16:00 on May 31)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,157 mm (1 mm decrease since 7:00 on May 31)	O.P.+ 3,168 mm (1 mm decrease since 7:00 on May 31)	—
	Water level of Turbine Building	O.P.+ 3,377 mm (8 mm increase since 7:00 on May 31)	O.P.+ 3,099 mm (2 mm decrease since 7:00 on May 31)	O.P.+ 3,090 mm (2 mm decrease since 7:00 on May 31)	O.P.+ 3,090 mm (2 mm decrease since 7:00 on May 31)
	Water level of Reactor Building	O.P.+ 4,470 mm (20 mm decrease since 7:00 on May 31)	O.P.+ 3,310 mm (2 mm decrease since 7:00 on May 31)	O.P.+ 3,191 mm (3 mm decrease since 7:00 on May 31)	O.P.+ 3,104 mm (3 mm decrease since 7:00 on May 31)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,595 mm (Increase from initial level:5,812 mm, 5 mm increase since 7:00 on May 31) O.P.+ 3,265 mm (Increase from initial level:3,991 mm, 418 mm increase since 7:00 on May 31) O.P.+ 4,428 mm (Water level from floor:632 mm, 5 mm increase since 7:00 on May 31)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:34 on May 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:15 on May 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:35 on May 31 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 8:36 AM on May 31, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for filter cleaning. At 3:35 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved.				

For quick publication of the data of water level, values are provided as reference values.