

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on June 1)**

Water Level of the accumulated water (at 16:00 on June 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,156 mm (4 mm increase since 7:00 on June 1)	O.P.+ 3,166 mm (3 mm increase since 7:00 on June 1)	—
	Water level of Turbine Building	O.P.+ 3,369 mm (18 mm decrease since 7:00 on June 1)	O.P.+ 3,098 mm (1 mm increase since 7:00 on June 1)	O.P.+ 3,104 mm (17 mm increase since 7:00 on June 1)	O.P.+ 3,085 mm (No change since 7:00 on June 1)
	Water level of Reactor Building	O.P.+ 4,428 mm (25 mm decrease since 7:00 on June 1)	O.P.+ 3,307 mm (1 mm increase since 7:00 on June 1)	O.P.+ 3,201 mm (12 mm increase since 7:00 on June 1)	O.P.+ 3,098 mm (1 mm decrease since 7:00 on June 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,610 mm (Increase from initial level:5,827 mm, 7 mm increase since 7:00 on June 1) O.P.+ 3,250 mm (Increase from initial level:3,976 mm, 79 mm decrease since 7:00 on June 1) O.P.+ 4,441 mm (Water level from floor:645 mm, 4 mm increase since 7:00 on June 1)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building →Basement of Unit 2 Turbine Building Currently being transferred (Since 14:22 on June 1)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:34 on May 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 9:15 on May 19 to 9:58 on June 1)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed (From 10:00 on June 1 to 16:00 on June 1)		
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:35 on May 31   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.