

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on June 4)**

Water Level of the accumulated water (at 16:00 on June 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,211 mm (4 mm decrease since 7:00 on June 4)	O.P.+ 3,201 mm (2 mm decrease since 7:00 on June 4)	—
	Water level of Turbine Building	O.P.+ 2,757 mm (9 mm increase since 7:00 on June 4)	O.P.+ 3,148 mm (4 mm decrease since 7:00 on June 4)	O.P.+ 3,128 mm (7 mm decrease since 7:00 on June 4)	O.P.+ 3,120 mm (2 mm decrease since 7:00 on June 4)
	Water level of Reactor Building	O.P.+ 4,343 mm (22 mm decrease since 7:00 on June 4)	O.P.+ 3,362 mm (4 mm decrease since 7:00 on June 4)	O.P.+ 3,233 mm (7 mm decrease since 7:00 on June 4)	O.P.+ 3,134 mm (No change since 7:00 on June 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,649 mm (Increase from initial level:5,866 mm, 4 mm increase since 7:00 on June 4) O.P.+ 2,776 mm (Increase from initial level:3,502 mm, 47 mm increase since 7:00 on June 4) O.P.+ 4,479 mm (Water level from floor:683 mm, 5 mm increase since 7:00 on June 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:34 on May 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:15 on June 3)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:35 on May 31 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.