

**Corrected**

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 5)**

Water Level of the accumulated water (at 7:00 on June 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,204 mm (7 mm decrease since 16:00 on June 4)	O.P.+ 3,196 mm (5 mm decrease since 16:00 on June 4)	—
	Water level of Turbine Building	O.P.+ 2,771 mm (14 mm increase since 16:00 on June 4)	O.P.+ 3,141 mm (7 mm decrease since 16:00 on June 4)	O.P.+ 3,121 mm (7 mm decrease since 16:00 on June 4)	O.P.+ 3,116 mm (4 mm decrease since 16:00 on June 4)
	Water level of Reactor Building	O.P.+ 4,338 mm (5 mm decrease since 16:00 on June 4)	O.P.+ 3,354 mm (8 mm decrease since 16:00 on June 4)	O.P.+ 3,225 mm (8 mm decrease since 16:00 on June 4)	O.P.+ 3,131 mm (3 mm decrease since 16:00 on June 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,657 mm (Increase from initial level:5,874 mm, 8 mm increase since 16:00 on June 4) O.P.+ 2,851 mm (Increase from initial level:3,577 mm, 75 mm increase since 16:00 on June 4) O.P.+ 4,491 mm (Water level from floor:695 mm, 12 mm increase since 16:00 on June 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:34 on May 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:15 on June 3)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:35 on May 31   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* On the last report, it said the water level of the High Temperature Incinerator Building (Centralized Radiation Waste Facility) at 9:00 AM on June 5 was "O.P. + 2,871mm (3,597mm increase from the initial value, 95mm increase from 4:00 PM on June 4)", however, it has been corrected to "O.P.+2,851mm (3,577mm increase from the initial value, 75mm increase from 4:00 PM on June 4)".				

For quick publication of the data of water level, values are provided as reference values.