

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on June 5)**

Water Level of the accumulated water (at 16:00 on June 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,198 mm (6 mm decrease since 7:00 on June 5)	O.P.+ 3,195 mm (1 mm decrease since 7:00 on June 5)	—
	Water level of Turbine Building	O.P.+ 2,778 mm (7 mm increase since 7:00 on June 5)	O.P.+ 3,136 mm (5 mm decrease since 7:00 on June 5)	O.P.+ 3,117 mm (4 mm decrease since 7:00 on June 5)	O.P.+ 3,113 mm (3 mm decrease since 7:00 on June 5)
	Water level of Reactor Building	O.P.+ 4,323 mm (15 mm decrease since 7:00 on June 5)	O.P.+ 3,352 mm (2 mm decrease since 7:00 on June 5)	O.P.+ 3,222 mm (3 mm decrease since 7:00 on June 5)	O.P.+ 3,127 mm (4 mm decrease since 7:00 on June 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,664 mm (Increase from initial level:5,881 mm, 7 mm increase since 7:00 on June 5) O.P.+ 2,903 mm (Increase from initial level:3,629 mm, 52 mm increase since 7:00 on June 5) O.P.+ 4,495 mm (Water level from floor:699 mm, 4 mm increase since 7:00 on June 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:34 on May 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:15 on June 3)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on June 5 to 16:00 on June 5)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:35 on May 31   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.