

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 6)**

Water Level of the accumulated water (at 7:00 on June 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,190 mm (8 mm decrease since 16:00 on June 5)	O.P.+ 3,190 mm (5 mm decrease since 16:00 on June 5)	—
	Water level of Turbine Building	O.P.+ 2,791 mm (13 mm increase since 16:00 on June 5)	O.P.+ 3,130 mm (6 mm decrease since 16:00 on June 5)	O.P.+ 3,112 mm (5 mm decrease since 16:00 on June 5)	O.P.+ 3,108 mm (5 mm decrease since 16:00 on June 5)
	Water level of Reactor Building	O.P.+ 4,317 mm (6 mm decrease since 16:00 on June 5)	O.P.+ 3,346 mm (6 mm decrease since 16:00 on June 5)	O.P.+ 3,216 mm (6 mm decrease since 16:00 on June 5)	O.P.+ 3,122 mm (5 mm decrease since 16:00 on June 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,672 mm (Increase from initial level:5,889 mm, 8 mm increase since 16:00 on June 5) O.P.+ 2,986 mm (Increase from initial level:3,712 mm, 83 mm increase since 16:00 on June 5) O.P.+ 4,505 mm (Water level from floor:709 mm, 10 mm increase since 16:00 on June 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:34 on May 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:15 on June 3)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:35 on May 31 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.