

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 7)**

Water Level of the accumulated water (at 7:00 on June 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,178 mm (8 mm decrease since 16:00 on June 6)	O.P.+ 3,181 mm (5 mm decrease since 16:00 on June 6)	—
	Water level of Turbine Building	O.P.+ 2,812 mm (13 mm increase since 16:00 on June 6)	O.P.+ 3,120 mm (6 mm decrease since 16:00 on June 6)	O.P.+ 3,103 mm (5 mm decrease since 16:00 on June 6)	O.P.+ 3,099 mm (6 mm decrease since 16:00 on June 6)
	Water level of Reactor Building	O.P.+ 4,333 mm (20 mm increase since 16:00 on June 6)	O.P.+ 3,332 mm (9 mm decrease since 16:00 on June 6)	O.P.+ 3,208 mm (6 mm decrease since 16:00 on June 6)	O.P.+ 3,115 mm (5 mm decrease since 16:00 on June 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,758 mm (Increase from initial level:5,975 mm, 19 mm increase since 16:00 on June 6) O.P.+ 3,292 mm (Increase from initial level:4,018 mm, 185 mm increase since 16:00 on June 6) O.P.+ 4,271 mm (Water level from floor:475 mm, 32 mm decrease since 16:00 on June 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:34 on May 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 10:15 on June 3 to 8:25 on June 7)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:35 on May 31 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* From 5:27 PM on June 6 to 8:04 AM on June 7, the accumulated water was transferred from the trench (Common Pool Duct) between Central Radioactive Waste Treatment Facility (Process Main Building) and Central Radioactive Waste Treatment Facility (High Tem				

For quick publication of the data of water level, values are provided as reference values.