

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on June 7)**

Water Level of the accumulated water (at 16:00 on June 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,174 mm (4 mm decrease since 7:00 on June 7)	O.P.+ 3,184 mm (3 mm increase since 7:00 on June 7)	—
	Water level of Turbine Building	O.P.+ 2,820 mm (8 mm increase since 7:00 on June 7)	O.P.+ 3,115 mm (5 mm decrease since 7:00 on June 7)	O.P.+ 3,123 mm (20 mm increase since 7:00 on June 7)	O.P.+ 3,097 mm (2 mm decrease since 7:00 on June 7)
	Water level of Reactor Building	O.P.+ 4,316 mm (17 mm decrease since 7:00 on June 7)	O.P.+ 3,328 mm (4 mm decrease since 7:00 on June 7)	O.P.+ 3,224 mm (16 mm increase since 7:00 on June 7)	O.P.+ 3,112 mm (3 mm decrease since 7:00 on June 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,763 mm (Increase from initial level:5,980 mm, 5 mm increase since 7:00 on June 7) O.P.+ 3,180 mm (Increase from initial level:3,906 mm, 112 mm decrease since 7:00 on June 7) O.P.+ 4,276 mm (Water level from floor:480 mm, 5 mm increase since 7:00 on June 7)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:34 on May 27)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on June 7 to 16:00 on June 7)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:35 on May 31 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.