

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 8)**

Water Level of the accumulated water (at 7:00 on June 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,165 mm (9 mm decrease since 16:00 on June 7)	O.P.+ 3,199 mm (15 mm increase since 16:00 on June 7)	—
	Water level of Turbine Building	O.P.+ 2,832 mm (12 mm increase since 16:00 on June 7)	O.P.+ 3,107 mm (8 mm decrease since 16:00 on June 7)	O.P.+ 3,142 mm (19 mm increase since 16:00 on June 7)	O.P.+ 3,107 mm (10 mm increase since 16:00 on June 7)
	Water level of Reactor Building	O.P.+ 4,312 mm (4 mm decrease since 16:00 on June 7)	O.P.+ 3,322 mm (6 mm decrease since 16:00 on June 7)	O.P.+ 3,246 mm (22 mm increase since 16:00 on June 7)	O.P.+ 3,120 mm (8 mm increase since 16:00 on June 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,770 mm (Increase from initial level:5,987 mm, 7 mm increase since 16:00 on June 7) O.P.+ 2,947 mm (Increase from initial level:3,673 mm, 233 mm decrease since 16:00 on June 7) O.P.+ 4,283 mm (Water level from floor:487 mm, 7 mm increase since 16:00 on June 7)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:34 on May 27)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:21 on June 8 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 8:21 AM on June 8, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for filter cleaning.				

For quick publication of the data of water level, values are provided as reference values.