

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on June 8)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on June 8)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,160 mm (5 mm decrease since 7:00 on June 8)	O.P.+ 3,208 mm (9 mm increase since 7:00 on June 8)	—
	Water level of Turbine Building	O.P.+ 2,839 mm (7 mm increase since 7:00 on June 8)	O.P.+ 3,102 mm (5 mm decrease since 7:00 on June 8)	O.P.+ 3,151 mm (9 mm increase since 7:00 on June 8)	O.P.+ 3,114 mm (7 mm increase since 7:00 on June 8)
	Water level of Reactor Building	O.P.+ 4,285 mm (27 mm decrease since 7:00 on June 8)	O.P.+ 3,317 mm (5 mm decrease since 7:00 on June 8)	O.P.+ 3,255 mm (9 mm increase since 7:00 on June 8)	O.P.+ 3,127 mm (7 mm increase since 7:00 on June 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,777 mm (Increase from initial level:5,994 mm, 7 mm increase since 7:00 on June 8) O.P.+ 3,034 mm (Increase from initial level:3,760 mm, 87 mm increase since 7:00 on June 8) O.P.+ 4,287 mm (Water level from floor:491 mm, 4 mm increase since 7:00 on June 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:34 on May 27)	—	—
		Unit 5 and 6 Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on June 8 to 16:00 on June 8)			
Operation condition of water treatment facility	Cesium Adsorption Apparatus: Since 9:50 on April 26 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:05 on June 8 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance				
Notes	* At 8:21 AM on June 8, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for filter cleaning. At 12:05 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved.				

For quick publication of the data of water level, values are provided as reference values.