

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 11)**

Water Level of the accumulated water (at 7:00 on June 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,138 mm (4 mm decrease since 16:00 on June 10)	O.P.+ 3,248 mm (3 mm decrease since 16:00 on June 10)	—
	Water level of Turbine Building	O.P.+ 2,896 mm (12 mm increase since 16:00 on June 10)	O.P.+ 3,083 mm (4 mm decrease since 16:00 on June 10)	O.P.+ 3,178 mm (13 mm decrease since 16:00 on June 10)	O.P.+ 3,163 mm (No change since 16:00 on June 10)
	Water level of Reactor Building	O.P.+ 4,431 mm (11 mm increase since 16:00 on June 10)	O.P.+ 3,298 mm (4 mm decrease since 16:00 on June 10)	O.P.+ 3,290 mm (13 mm decrease since 16:00 on June 10)	O.P.+ 3,174 mm (No change since 16:00 on June 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,809 mm (Increase from initial level:6,026 mm, 1 mm increase since 16:00 on June 10) O.P.+ 2,603 mm (Increase from initial level:3,329 mm, 66 mm increase since 16:00 on June 10) O.P.+ 4,319 mm (Water level from floor:523 mm, 8 mm increase since 16:00 on June 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:34 on May 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:26 on June 10)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:05 on June 8 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.