

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on June 11)**

Water Level of the accumulated water (at 16:00 on June 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,135 mm (3 mm decrease since 7:00 on June 11)	O.P.+ 3,246 mm (2 mm decrease since 7:00 on June 11)	—
	Water level of Turbine Building	O.P.+ 2,904 mm (8 mm increase since 7:00 on June 11)	O.P.+ 3,081 mm (2 mm decrease since 7:00 on June 11)	O.P.+ 3,173 mm (5 mm decrease since 7:00 on June 11)	O.P.+ 3,162 mm (1 mm decrease since 7:00 on June 11)
	Water level of Reactor Building	O.P.+ 4,423 mm (8 mm decrease since 7:00 on June 11)	O.P.+ 3,294 mm (4 mm decrease since 7:00 on June 11)	O.P.+ 3,284 mm (6 mm decrease since 7:00 on June 11)	O.P.+ 3,173 mm (1 mm decrease since 7:00 on June 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,814 mm (Increase from initial level:6,031 mm, 5 mm increase since 7:00 on June 11) O.P.+ 2,648 mm (Increase from initial level:3,374 mm, 45 mm increase since 7:00 on June 11) O.P.+ 4,323 mm (Water level from floor:527 mm, 4 mm increase since 7:00 on June 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:34 on May 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:26 on June 10)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:05 on June 8 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.