

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 12)**

Water Level of the accumulated water (at 7:00 on June 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,130 mm (5 mm decrease since 16:00 on June 11)	O.P.+ 3,241 mm (5 mm decrease since 16:00 on June 11)	—
	Water level of Turbine Building	O.P.+ 2,916 mm (12 mm increase since 16:00 on June 11)	O.P.+ 3,076 mm (5 mm decrease since 16:00 on June 11)	O.P.+ 3,165 mm (8 mm decrease since 16:00 on June 11)	O.P.+ 3,157 mm (5 mm decrease since 16:00 on June 11)
	Water level of Reactor Building	O.P.+ 4,414 mm (9 mm decrease since 16:00 on June 11)	O.P.+ 3,290 mm (4 mm decrease since 16:00 on June 11)	O.P.+ 3,274 mm (10 mm decrease since 16:00 on June 11)	O.P.+ 3,170 mm (3 mm decrease since 16:00 on June 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,821 mm (Increase from initial level:6,038 mm, 7 mm increase since 16:00 on June 11) O.P.+ 2,716 mm (Increase from initial level:3,442 mm, 68 mm increase since 16:00 on June 11) O.P.+ 4,330 mm (Water level from floor:534 mm, 7 mm increase since 16:00 on June 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:34 on May 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:26 on June 10)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on April 26 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:05 on June 8 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.