

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on June 12)**

| | | | | | |
|---|--|---|--|--|---|
| Water Level of the accumulated water (at 16:00 on June 12) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 3,126 mm (4 mm decrease since 7:00 on June 12) | O.P.+ 3,240 mm (1 mm decrease since 7:00 on June 12) | — |
| | Water level of Turbine Building | O.P.+ 2,923 mm (7 mm increase since 7:00 on June 12) | O.P.+ 3,072 mm (4 mm decrease since 7:00 on June 12) | O.P.+ 3,160 mm (5 mm decrease since 7:00 on June 12) | O.P.+ 3,155 mm (2 mm decrease since 7:00 on June 12) |
| | Water level of Reactor Building | O.P.+ 4,380 mm (34 mm decrease since 7:00 on June 12) | O.P.+ 3,287 mm (3 mm decrease since 7:00 on June 12) | O.P.+ 3,271 mm (3 mm decrease since 7:00 on June 12) | O.P.+ 3,167 mm (3 mm decrease since 7:00 on June 12) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | O.P.+ 4,827 mm (Increase from initial level:6,044 mm, 6 mm increase since 7:00 on June 12) O.P.+ 2,766 mm (Increase from initial level:3,492 mm, 50 mm increase since 7:00 on June 12) O.P.+ 4,333 mm (Water level from floor:537 mm, 3 mm increase since 7:00 on June 12) | | |
| Situation of transfer of the accumulated water | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | | — | Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:34 on May 27) | Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:26 on June 10) | — |
| | | Unit 5 and 6 | | | |
| | | — | | | |
| Operation condition of water treatment facility | | Cesium Adsorption Apparatus: Since 9:50 on April 26 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:05 on June 8 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | |
| Notes | | | | | |

For quick publication of the data of water level, values are provided as reference values.