

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 14)**

Water Level of the accumulated water (at 7:00 on June 14)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,109 mm (11 mm decrease since 16:00 on June 13)	O.P.+ 3,226 mm (6 mm decrease since 16:00 on June 13)	—
	Water level of Turbine Building	O.P.+ 2,954 mm (11 mm increase since 16:00 on June 13)	O.P.+ 3,056 mm (10 mm decrease since 16:00 on June 13)	O.P.+ 3,144 mm (6 mm decrease since 16:00 on June 13)	O.P.+ 3,140 mm (6 mm decrease since 16:00 on June 13)
	Water level of Reactor Building	O.P.+ 4,364 mm (16 mm decrease since 16:00 on June 13)	O.P.+ 3,264 mm (14 mm decrease since 16:00 on June 13)	O.P.+ 3,256 mm (6 mm decrease since 16:00 on June 13)	O.P.+ 3,153 mm (6 mm decrease since 16:00 on June 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,740 mm (Increase from initial level:5,957 mm, 93 mm decrease since 16:00 on June 13) O.P.+ 2,992 mm (Increase from initial level:3,718 mm, 90 mm increase since 16:00 on June 13) O.P.+ 4,351 mm (Water level from floor:555 mm, 7 mm increase since 16:00 on June 13)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:34 on May 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:26 on June 10)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:08 on June 13 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:05 on June 8 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.