

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on June 14)**

Water Level of the accumulated water (at 16:00 on June 14)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,118 mm (9 mm increase since 7:00 on June 14)	O.P.+ 3,224 mm (2 mm decrease since 7:00 on June 14)	—
	Water level of Turbine Building	O.P.+ 2,961 mm (7 mm increase since 7:00 on June 14)	O.P.+ 3,063 mm (7 mm increase since 7:00 on June 14)	O.P.+ 3,141 mm (3 mm decrease since 7:00 on June 14)	O.P.+ 3,138 mm (2 mm decrease since 7:00 on June 14)
	Water level of Reactor Building	O.P.+ 4,354 mm (10 mm decrease since 7:00 on June 14)	O.P.+ 3,259 mm (5 mm decrease since 7:00 on June 14)	O.P.+ 3,253 mm (3 mm decrease since 7:00 on June 14)	O.P.+ 3,150 mm (3 mm decrease since 7:00 on June 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,689 mm (Increase from initial level:5,906 mm, 51 mm decrease since 7:00 on June 14) O.P.+ 3,011 mm (Increase from initial level:3,737 mm, 19 mm increase since 7:00 on June 14) O.P.+ 4,355 mm (Water level from floor:559 mm, 4 mm increase since 7:00 on June 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 14:34 on May 27 to 14:16 on June 14)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:26 on June 10)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on June 14 to 16:00 on June 14)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:08 on June 13 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:05 on June 8 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.