

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 15)**

Water Level of the accumulated water (at 7:00 on June 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,165 mm (47 mm increase since 16:00 on June 14)	O.P.+ 3,220 mm (4 mm decrease since 16:00 on June 14)	—
	Water level of Turbine Building	O.P.+ 2,973 mm (12 mm increase since 16:00 on June 14)	O.P.+ 3,104 mm (41 mm increase since 16:00 on June 14)	O.P.+ 3,136 mm (5 mm decrease since 16:00 on June 14)	O.P.+ 3,131 mm (7 mm decrease since 16:00 on June 14)
	Water level of Reactor Building	O.P.+ 4,350 mm (4 mm decrease since 16:00 on June 14)	O.P.+ 3,297 mm (38 mm increase since 16:00 on June 14)	O.P.+ 3,247 mm (6 mm decrease since 16:00 on June 14)	O.P.+ 3,143 mm (7 mm decrease since 16:00 on June 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,595 mm (Increase from initial level:5,812 mm, 94 mm decrease since 16:00 on June 14) O.P.+ 2,749 mm (Increase from initial level:3,475 mm, 262 mm decrease since 16:00 on June 14) O.P.+ 4,362 mm (Water level from floor:566 mm, 7 mm increase since 16:00 on June 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:26 on June 10)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:08 on June 13 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:05 on June 8 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.