

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on June 15)**

Water Level of the accumulated water (at 16:00 on June 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,194 mm (29 mm increase since 7:00 on June 15)	O.P.+ 3,217 mm (3 mm decrease since 7:00 on June 15)	—
	Water level of Turbine Building	O.P.+ 2,980 mm (7 mm increase since 7:00 on June 15)	O.P.+ 3,132 mm (28 mm increase since 7:00 on June 15)	O.P.+ 3,131 mm (5 mm decrease since 7:00 on June 15)	O.P.+ 3,128 mm (3 mm decrease since 7:00 on June 15)
	Water level of Reactor Building	O.P.+ 4,324 mm (26 mm decrease since 7:00 on June 15)	O.P.+ 3,321 mm (24 mm increase since 7:00 on June 15)	O.P.+ 3,244 mm (3 mm decrease since 7:00 on June 15)	O.P.+ 3,142 mm (1 mm decrease since 7:00 on June 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,541 mm (Increase from initial level:5,758 mm, 54 mm decrease since 7:00 on June 15) O.P.+ 2,630 mm (Increase from initial level:3,356 mm, 119 mm decrease since 7:00 on June 15) O.P.+ 4,365 mm (Water level from floor:569 mm, 3 mm increase since 7:00 on June 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:26 on June 10)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on June 15 to 16:00 on June 15)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:08 on June 13 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:05 on June 8 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.