

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 18)**

Water Level of the accumulated water (at 7:00 on June 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,215 mm (16 mm decrease since 16:00 on June 17)	O.P.+ 3,198 mm (5 mm decrease since 16:00 on June 17)	—
	Water level of Turbine Building	O.P.+ 3,028 mm (12 mm increase since 16:00 on June 17)	O.P.+ 3,151 mm (14 mm decrease since 16:00 on June 17)	O.P.+ 3,113 mm (4 mm decrease since 16:00 on June 17)	O.P.+ 3,108 mm (5 mm decrease since 16:00 on June 17)
	Water level of Reactor Building	O.P.+ 4,411 mm (32 mm increase since 16:00 on June 17)	O.P.+ 3,351 mm (13 mm decrease since 16:00 on June 17)	O.P.+ 3,227 mm (8 mm decrease since 16:00 on June 17)	O.P.+ 3,122 mm (5 mm decrease since 16:00 on June 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,965 mm (Increase from initial level:5,182 mm, 135 mm decrease since 16:00 on June 17) O.P.+ 2,658 mm (Increase from initial level:3,384 mm, 57 mm increase since 16:00 on June 17) O.P.+ 4,395 mm (Water level from floor:599 mm, 8 mm increase since 16:00 on June 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:12 on June 16)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:26 on June 10)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:08 on June 13 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:25 on June 16 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.