

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 19)**

Water Level of the accumulated water (at 7:00 on June 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,192 mm (15 mm decrease since 16:00 on June 18)	O.P.+ 3,191 mm (5 mm decrease since 16:00 on June 18)	—
	Water level of Turbine Building	O.P.+ 3,045 mm (11 mm increase since 16:00 on June 18)	O.P.+ 3,131 mm (13 mm decrease since 16:00 on June 18)	O.P.+ 3,105 mm (6 mm decrease since 16:00 on June 18)	O.P.+ 3,100 mm (5 mm decrease since 16:00 on June 18)
	Water level of Reactor Building	O.P.+ 4,405 mm (12 mm increase since 16:00 on June 18)	O.P.+ 3,335 mm (10 mm decrease since 16:00 on June 18)	O.P.+ 3,219 mm (4 mm decrease since 16:00 on June 18)	O.P.+ 3,116 mm (4 mm decrease since 16:00 on June 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,757 mm (Increase from initial level:4,974 mm, 140 mm decrease since 16:00 on June 18) O.P.+ 2,767 mm (Increase from initial level:3,493 mm, 64 mm increase since 16:00 on June 18) O.P.+ 4,407 mm (Water level from floor:611 mm, 8 mm increase since 16:00 on June 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:12 on June 16)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:26 on June 10)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:08 on June 13 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:25 on June 16 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.