

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on June 20)**

Water Level of the accumulated water (at 16:00 on June 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,196 mm (1 mm increase since 7:00 on June 20)	O.P.+ 3,234 mm (No change since 7:00 on June 20)	—
	Water level of Turbine Building	O.P.+ 3,105 mm (17 mm increase since 7:00 on June 20)	O.P.+ 3,134 mm (1 mm increase since 7:00 on June 20)	O.P.+ 3,148 mm (7 mm increase since 7:00 on June 20)	O.P.+ 3,138 mm (39 mm increase since 7:00 on June 20)
	Water level of Reactor Building	O.P.+ 4,689 mm (82 mm increase since 7:00 on June 20)	O.P.+ 3,336 mm (16 mm decrease since 7:00 on June 20)	O.P.+ 3,267 mm (14 mm decrease since 7:00 on June 20)	O.P.+ 3,146 mm (2 mm increase since 7:00 on June 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,476 mm (Increase from initial level:4,693 mm, 76 mm decrease since 7:00 on June 20) O.P.+ 2,957 mm (Increase from initial level:3,683 mm, 64 mm increase since 7:00 on June 20) O.P.+ 4,425 mm (Water level from floor:629 mm, 5 mm increase since 7:00 on June 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:12 on June 16)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:26 on June 10)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:08 on June 13 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:25 on June 16 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- We informed the data as of 4:00 PM on June 19 as the data is missing due to a problem with the camera.				

For quick publication of the data of water level, values are provided as reference values.