

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 21)**

Water Level of the accumulated water (at 7:00 on June 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,197 mm (1 mm increase since 16:00 on June 20)	O.P.+ 3,238 mm (4 mm increase since 16:00 on June 20)	—
	Water level of Turbine Building	O.P.+ 3,129 mm (24 mm increase since 16:00 on June 20)	O.P.+ 3,134 mm (No change since 16:00 on June 20)	O.P.+ 3,148 mm (No change since 16:00 on June 20)	O.P.+ 3,141 mm (3 mm increase since 16:00 on June 20)
	Water level of Reactor Building	O.P.+ 4,753 mm (64 mm increase since 16:00 on June 20)	O.P.+ 3,334 mm (2 mm decrease since 16:00 on June 20)	O.P.+ 3,265 mm (2 mm decrease since 16:00 on June 20)	O.P.+ 3,152 mm (6 mm increase since 16:00 on June 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,348 mm (Increase from initial level:4,565 mm, 128 mm decrease since 16:00 on June 20) O.P.+ 3,047 mm (Increase from initial level:3,773 mm, 90 mm increase since 16:00 on June 20) O.P.+ 4,434 mm (Water level from floor:638 mm, 9 mm increase since 16:00 on June 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:12 on June 16)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:26 on June 10)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:08 on June 13 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:25 on June 16 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.