

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 22)**

Water Level of the accumulated water (at 7:00 on June 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,195 mm (1 mm decrease since 16:00 on June 21)	O.P.+ 3,240 mm (No change since 16:00 on June 21)	—
	Water level of Turbine Building	O.P.+ 3,160 mm (18 mm increase since 16:00 on June 21)	O.P.+ 3,132 mm (2 mm decrease since 16:00 on June 21)	O.P.+ 3,146 mm (1 mm decrease since 16:00 on June 21)	O.P.+ 3,142 mm (1 mm decrease since 16:00 on June 21)
	Water level of Reactor Building	O.P.+ 4,747 mm (1 mm decrease since 16:00 on June 21)	O.P.+ 3,338 mm (3 mm increase since 16:00 on June 21)	O.P.+ 3,261 mm (3 mm decrease since 16:00 on June 21)	O.P.+ 3,153 mm (No change since 16:00 on June 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,323 mm (Increase from initial level:4,540 mm, 12 mm increase since 16:00 on June 21) O.P.+ 3,193 mm (Increase from initial level:3,919 mm, 87 mm increase since 16:00 on June 21) O.P.+ 4,448 mm (Water level from floor:652 mm, 9 mm increase since 16:00 on June 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:12 on June 16)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:26 on June 10)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:20 on June 22 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 8:20 AM on June 22, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for equipment cleaning.				

For quick publication of the data of water level, values are provided as reference values.