

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 25)**

Water Level of the accumulated water (at 7:00 on June 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,178 mm (5 mm decrease since 16:00 on June 24)	O.P.+ 3,295 mm (16 mm increase since 16:00 on June 24)	—
	Water level of Turbine Building	O.P.+ 3,241 mm (15 mm increase since 16:00 on June 24)	O.P.+ 3,118 mm (4 mm decrease since 16:00 on June 24)	O.P.+ 3,225 mm (18 mm increase since 16:00 on June 24)	O.P.+ 3,179 mm (16 mm increase since 16:00 on June 24)
	Water level of Reactor Building	O.P.+ 4,641 mm (31 mm decrease since 16:00 on June 24)	O.P.+ 3,326 mm (3 mm decrease since 16:00 on June 24)	O.P.+ 3,341 mm (19 mm increase since 16:00 on June 24)	O.P.+ 3,187 mm (14 mm increase since 16:00 on June 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,371 mm (Increase from initial level:4,588 mm, 9 mm increase since 16:00 on June 24) O.P.+ 2,901 mm (Increase from initial level:3,627 mm, 224 mm decrease since 16:00 on June 24) O.P.+ 4,492 mm (Water level from floor:696 mm, 11 mm increase since 16:00 on June 24)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:12 on June 16)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:22 on June 22 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.