

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 26)**

Water Level of the accumulated water (at 7:00 on June 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,170 mm (7 mm decrease since 16:00 on June 25)	O.P.+ 3,290 mm (5 mm decrease since 16:00 on June 25)	—
	Water level of Turbine Building	O.P.+ 3,264 mm (14 mm increase since 16:00 on June 25)	O.P.+ 3,110 mm (6 mm decrease since 16:00 on June 25)	O.P.+ 3,206 mm (12 mm decrease since 16:00 on June 25)	O.P.+ 3,190 mm (1 mm increase since 16:00 on June 25)
	Water level of Reactor Building	O.P.+ 4,589 mm (28 mm decrease since 16:00 on June 25)	O.P.+ 3,320 mm (4 mm decrease since 16:00 on June 25)	O.P.+ 3,327 mm (12 mm decrease since 16:00 on June 25)	O.P.+ 3,199 mm (3 mm increase since 16:00 on June 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,712 mm (Increase from initial level:4,929 mm, 177 mm increase since 16:00 on June 25) O.P.+ 2,613 mm (Increase from initial level:3,339 mm, 171 mm decrease since 16:00 on June 25) O.P.+ 4,255 mm (Water level from floor:459 mm, 28 mm decrease since 16:00 on June 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:12 on June 16)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:13 on June 25)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:22 on June 22 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.