

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on June 26)**

Water Level of the accumulated water (at 16:00 on June 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,170 mm (No change since 7:00 on June 26)	O.P.+ 3,293 mm (3 mm increase since 7:00 on June 26)	—
	Water level of Turbine Building	O.P.+ 3,272 mm (8 mm increase since 7:00 on June 26)	O.P.+ 3,107 mm (3 mm decrease since 7:00 on June 26)	O.P.+ 3,204 mm (2 mm decrease since 7:00 on June 26)	O.P.+ 3,192 mm (2 mm increase since 7:00 on June 26)
	Water level of Reactor Building	O.P.+ 4,563 mm (26 mm decrease since 7:00 on June 26)	O.P.+ 3,318 mm (2 mm decrease since 7:00 on June 26)	O.P.+ 3,323 mm (4 mm decrease since 7:00 on June 26)	O.P.+ 3,201 mm (2 mm increase since 7:00 on June 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,748 mm (Increase from initial level:4,965 mm, 36 mm increase since 7:00 on June 26) O.P.+ 2,612 mm (Increase from initial level:3,338 mm, 1 mm decrease since 7:00 on June 26) O.P.+ 4,260 mm (Water level from floor:464 mm, 5 mm increase since 7:00 on June 26)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:12 on June 16)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on June 26)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:22 on June 22 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- From 10:13 AM on June 25 to 10:00 AM on June 26, transfer of the accumulated water from Unit 3 Turbine Building basement to Central Radioactive Waste Treatment Facility (Process Main Building) was conducted.				

For quick publication of the data of water level, values are provided as reference values.