

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 27)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on June 27)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,164 mm (6 mm decrease since 16:00 on June 26)	O.P.+ 3,289 mm (4 mm decrease since 16:00 on June 26)	—
	Water level of Turbine Building	O.P.+ 3,285 mm (13 mm increase since 16:00 on June 26)	O.P.+ 3,101 mm (6 mm decrease since 16:00 on June 26)	O.P.+ 3,198 mm (6 mm decrease since 16:00 on June 26)	O.P.+ 3,188 mm (4 mm decrease since 16:00 on June 26)
	Water level of Reactor Building	O.P.+ 4,536 mm (27 mm decrease since 16:00 on June 26)	O.P.+ 3,314 mm (4 mm decrease since 16:00 on June 26)	O.P.+ 3,317 mm (6 mm decrease since 16:00 on June 26)	O.P.+ 3,197 mm (4 mm decrease since 16:00 on June 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,753 mm (Increase from initial level:4,970 mm, 5 mm increase since 16:00 on June 26) O.P.+ 2,693 mm (Increase from initial level:3,419 mm, 81 mm increase since 16:00 on June 26) O.P.+ 4,267 mm (Water level from floor:471 mm, 7 mm increase since 16:00 on June 26)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:12 on June 16)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on June 26)	—
		Unit 5 and 6 —			
Operation condition of water treatment facility	Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:30 on June 26 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance				
Notes	- At 8:30 AM on June 27, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for filter cleaning.				

For quick publication of the data of water level, values are provided as reference values.