

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on June 27)**

Water Level of the accumulated water (at 16:00 on June 27)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,159 mm (5 mm decrease since 7:00 on June 27)	O.P.+ 3,287 mm (2 mm decrease since 7:00 on June 27)	—
	Water level of Turbine Building	O.P.+ 3,292 mm (7 mm increase since 7:00 on June 27)	O.P.+ 3,098 mm (3 mm decrease since 7:00 on June 27)	O.P.+ 3,196 mm (2 mm decrease since 7:00 on June 27)	O.P.+ 3,188 mm (No change since 7:00 on June 27)
	Water level of Reactor Building	O.P.+ 4,494 mm (42 mm decrease since 7:00 on June 27)	O.P.+ 3,312 mm (2 mm decrease since 7:00 on June 27)	O.P.+ 3,314 mm (3 mm decrease since 7:00 on June 27)	O.P.+ 3,197 mm (No change since 7:00 on June 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,758 mm (Increase from initial level:4,975 mm, 5 mm increase since 7:00 on June 27) O.P.+ 3,089 mm (Increase from initial level:3,815 mm, 396 mm increase since 7:00 on June 27) O.P.+ 4,272 mm (Water level from floor:476 mm, 5 mm increase since 7:00 on June 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:12 on June 16)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on June 26)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:33 on June 27   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 8:30 AM on June 27, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for filter cleaning. After the filter cleaning, the apparatus was restarted at 5:33 PM on the same day.				

For quick publication of the data of water level, values are provided as reference values.