

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 28)**

Water Level of the accumulated water (at 7:00 on June 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,151 mm (8 mm decrease since 16:00 on June 27)	O.P.+ 3,283 mm (4 mm decrease since 16:00 on June 27)	—
	Water level of Turbine Building	O.P.+ 3,306 mm (14 mm increase since 16:00 on June 27)	O.P.+ 3,091 mm (7 mm decrease since 16:00 on June 27)	O.P.+ 3,190 mm (6 mm decrease since 16:00 on June 27)	O.P.+ 3,183 mm (5 mm decrease since 16:00 on June 27)
	Water level of Reactor Building	O.P.+ 4,480 mm (14 mm decrease since 16:00 on June 27)	O.P.+ 3,306 mm (6 mm decrease since 16:00 on June 27)	O.P.+ 3,310 mm (4 mm decrease since 16:00 on June 27)	O.P.+ 3,194 mm (3 mm decrease since 16:00 on June 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,765 mm (Increase from initial level:4,982 mm, 7 mm increase since 16:00 on June 27) O.P.+ 3,233 mm (Increase from initial level:3,959 mm, 144 mm increase since 16:00 on June 27) O.P.+ 4,279 mm (Water level from floor:483 mm, 7 mm increase since 16:00 on June 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:12 on June 16)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on June 26)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:33 on June 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.