

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on June 28)**

Water Level of the accumulated water (at 16:00 on June 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,146 mm (5 mm decrease since 7:00 on June 28)	O.P.+ 3,282 mm (1 mm decrease since 7:00 on June 28)	—
	Water level of Turbine Building	O.P.+ 3,313 mm (7 mm increase since 7:00 on June 28)	O.P.+ 3,088 mm (3 mm decrease since 7:00 on June 28)	O.P.+ 3,188 mm (2 mm decrease since 7:00 on June 28)	O.P.+ 3,180 mm (3 mm decrease since 7:00 on June 28)
	Water level of Reactor Building	O.P.+ 4,450 mm (30 mm decrease since 7:00 on June 28)	O.P.+ 3,302 mm (4 mm decrease since 7:00 on June 28)	O.P.+ 3,310 mm (No change since 7:00 on June 28)	O.P.+ 3,190 mm (4 mm decrease since 7:00 on June 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,769 mm (Increase from initial level:4,986 mm, 4 mm increase since 7:00 on June 28) O.P.+ 3,288 mm (Increase from initial level:4,014 mm, 55 mm increase since 7:00 on June 28) O.P.+ 4,284 mm (Water level from floor:488 mm, 5 mm increase since 7:00 on June 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:12 on June 16)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on June 26)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:33 on June 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.