

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 29)**

Water Level of the accumulated water (at 7:00 on June 29)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,141 mm (5 mm decrease since 16:00 on June 28)	O.P.+ 3,278 mm (4 mm decrease since 16:00 on June 28)	—
	Water level of Turbine Building	O.P.+ 3,325 mm (12 mm increase since 16:00 on June 28)	O.P.+ 3,081 mm (7 mm decrease since 16:00 on June 28)	O.P.+ 3,183 mm (5 mm decrease since 16:00 on June 28)	O.P.+ 3,175 mm (5 mm decrease since 16:00 on June 28)
	Water level of Reactor Building	O.P.+ 4,440 mm (10 mm decrease since 16:00 on June 28)	O.P.+ 3,296 mm (6 mm decrease since 16:00 on June 28)	O.P.+ 3,303 mm (7 mm decrease since 16:00 on June 28)	O.P.+ 3,186 mm (4 mm decrease since 16:00 on June 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,778 mm (Increase from initial level:4,995 mm, 9 mm increase since 16:00 on June 28) O.P.+ 3,370 mm (Increase from initial level:4,096 mm, 82 mm increase since 16:00 on June 28) O.P.+ 4,293 mm (Water level from floor:497 mm, 9 mm increase since 16:00 on June 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:12 on June 16)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on June 26)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:33 on June 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.