

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on June 29)**

Water Level of the accumulated water (at 16:00 on June 29)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,138 mm (3 mm decrease since 7:00 on June 29)	O.P.+ 3,276 mm (2 mm decrease since 7:00 on June 29)	—
	Water level of Turbine Building	O.P.+ 3,332 mm (7 mm increase since 7:00 on June 29)	O.P.+ 3,082 mm (1 mm increase since 7:00 on June 29)	O.P.+ 3,180 mm (3 mm decrease since 7:00 on June 29)	O.P.+ 3,174 mm (1 mm decrease since 7:00 on June 29)
	Water level of Reactor Building	O.P.+ 4,417 mm (23 mm decrease since 7:00 on June 29)	O.P.+ 3,295 mm (1 mm decrease since 7:00 on June 29)	O.P.+ 3,298 mm (5 mm decrease since 7:00 on June 29)	O.P.+ 3,184 mm (2 mm decrease since 7:00 on June 29)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,785 mm (Increase from initial level:5,002 mm, 7 mm increase since 7:00 on June 29) O.P.+ 3,422 mm (Increase from initial level:4,148 mm, 52 mm increase since 7:00 on June 29) O.P.+ 4,299 mm (Water level from floor:503 mm, 6 mm increase since 7:00 on June 29)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building →Basement of Unit 2 Turbine Building Currently being transferred (Since 17:16 on June 29)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:12 on June 16)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on June 26)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:33 on June 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.