## Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 2)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on July 2)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,278 mm (50 mm increase since 16:00 on July 1)	O.P.+ 3,260 mm (3 mm decrease since 16:00 on July 1)	_
	Water level of Turbine Building	O.P.+ 2,730 mm (15 mm increase since 16:00 on July 1)	O.P.+ 3,207 mm (45 mm increase since 16:00 on July 1)	O.P.+ 3,162 mm (3 mm decrease since 16:00 on July 1)	O.P.+ 3,154 mm (4 mm decrease since 16:00 on July 1)
	Water level of Reactor Building	O.P.+ 4,403 mm (25 mm increase since 16:00 on July 1)	O.P.+ 3,415 mm (49 mm increase since 16:00 on July 1)	O.P.+ 3,281 mm (3 mm decrease since 16:00 on July 1)	O.P.+ 3,167 mm (3 mm decrease since 16:00 on July 1)
	Water level	Process Main Building	O.P.+ 3,817 mm (Increase from initial level:5,034 mm, 8 mm increase since 16:00 on July 1)		
	of each building in the Centralized Radiation Waste Treatment Facility	High Temperature Incinerator Building	O.P.+ 3,237 mm (Increase from initial level:3,963 mm, 308 mm decrease since 16:00 on July 1)		
		On-site Bunker Building	O.P.+ 4,334 mm (Water level from floor:538 mm, 8 mm increase since 16:00 on July 1)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		_	_	Basement of Unit 3 Turbine Building  →Centralized Radiation Waste  Treatment Facility (High  Temperature Incinerator Building)  Currently being transferred  (Since 10:14 on June 26)	_
		Unit 5 and 6			
		_			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:33 on June 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					
For quick publication of the data of water level, values are provided as reference values					