

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on July 2)**

Water Level of the accumulated water (at 16:00 on July 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,283 mm (5 mm increase since 7:00 on July 2)	O.P.+ 3,259 mm (1 mm decrease since 7:00 on July 2)	—
	Water level of Turbine Building	O.P.+ 2,737 mm (7 mm increase since 7:00 on July 2)	O.P.+ 3,211 mm (4 mm increase since 7:00 on July 2)	O.P.+ 3,161 mm (1 mm decrease since 7:00 on July 2)	O.P.+ 3,153 mm (1 mm decrease since 7:00 on July 2)
	Water level of Reactor Building	O.P.+ 4,420 mm (17 mm increase since 7:00 on July 2)	O.P.+ 3,424 mm (9 mm increase since 7:00 on July 2)	O.P.+ 3,281 mm (No change since 7:00 on July 2)	O.P.+ 3,166 mm (1 mm decrease since 7:00 on July 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,822 mm (Increase from initial level:5,039 mm, 5 mm increase since 7:00 on July 2) O.P.+ 3,215 mm (Increase from initial level:3,941 mm, 22 mm decrease since 7:00 on July 2) O.P.+ 4,338 mm (Water level from floor:542 mm, 4 mm increase since 7:00 on July 2)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:11 on July 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on June 26)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:33 on June 27   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.