

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on July 3)**

Water Level of the accumulated water (at 16:00 on July 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,264 mm (5 mm decrease since 7:00 on July 3)	O.P.+ 3,255 mm (2 mm increase since 7:00 on July 3)	—
	Water level of Turbine Building	O.P.+ 2,761 mm (9 mm increase since 7:00 on July 3)	O.P.+ 3,193 mm (6 mm decrease since 7:00 on July 3)	O.P.+ 3,154 mm (2 mm decrease since 7:00 on July 3)	O.P.+ 3,148 mm (1 mm decrease since 7:00 on July 3)
	Water level of Reactor Building	O.P.+ 4,431 mm (3 mm decrease since 7:00 on July 3)	O.P.+ 3,408 mm (6 mm decrease since 7:00 on July 3)	O.P.+ 3,273 mm (2 mm decrease since 7:00 on July 3)	O.P.+ 3,161 mm (1 mm decrease since 7:00 on July 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,835 mm (Increase from initial level:5,052 mm, 5 mm increase since 7:00 on July 3) O.P.+ 3,364 mm (Increase from initial level:4,090 mm, 59 mm increase since 7:00 on July 3) O.P.+ 4,352 mm (Water level from floor:556 mm, 5 mm increase since 7:00 on July 3)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:11 on July 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on June 26)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:33 on June 27   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.