

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 5)**

Water Level of the accumulated water (at 7:00 on July 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,241 mm (9 mm decrease since 16:00 on July 4)	O.P.+ 3,270 mm (16 mm increase since 16:00 on July 4)	—
	Water level of Turbine Building	O.P.+ 2,796 mm (14 mm increase since 16:00 on July 4)	O.P.+ 3,173 mm (8 mm decrease since 16:00 on July 4)	O.P.+ 3,192 mm (25 mm increase since 16:00 on July 4)	O.P.+ 3,153 mm (8 mm increase since 16:00 on July 4)
	Water level of Reactor Building	O.P.+ 4,433 mm (20 mm decrease since 16:00 on July 4)	O.P.+ 3,391 mm (5 mm decrease since 16:00 on July 4)	O.P.+ 3,308 mm (27 mm increase since 16:00 on July 4)	O.P.+ 3,163 mm (6 mm increase since 16:00 on July 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,853 mm (Increase from initial level:5,070 mm, 7 mm increase since 16:00 on July 4) O.P.+ 3,386 mm (Increase from initial level:4,112 mm, 244 mm decrease since 16:00 on July 4) O.P.+ 4,372 mm (Water level from floor:576 mm, 9 mm increase since 16:00 on July 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:11 on July 2)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:00 on July 4   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.