

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 6)**

Water Level of the accumulated water (at 7:00 on July 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,230 mm (6 mm decrease since 16:00 on July 5)	O.P.+ 3,323 mm (10 mm decrease since 16:00 on July 5)	—
	Water level of Turbine Building	O.P.+ 2,817 mm (14 mm increase since 16:00 on July 5)	O.P.+ 3,165 mm (4 mm decrease since 16:00 on July 5)	O.P.+ 3,248 mm (34 mm increase since 16:00 on July 5)	O.P.+ 3,196 mm (29 mm increase since 16:00 on July 5)
	Water level of Reactor Building	O.P.+ 4,441 mm (18 mm increase since 16:00 on July 5)	O.P.+ 3,384 mm (3 mm decrease since 16:00 on July 5)	O.P.+ 3,367 mm (41 mm increase since 16:00 on July 5)	O.P.+ 3,202 mm (30 mm increase since 16:00 on July 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,865 mm (Increase from initial level:5,082 mm, 8 mm increase since 16:00 on July 5) O.P.+ 3,023 mm (Increase from initial level:3,749 mm, 229 mm decrease since 16:00 on July 5) O.P.+ 4,385 mm (Water level from floor:589 mm, 9 mm increase since 16:00 on July 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:11 on July 2)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:00 on July 4   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.