

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on July 6)**

Water Level of the accumulated water (at 16:00 on July 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,227 mm (3 mm decrease since 7:00 on July 6)	O.P.+ 3,319 mm (4 mm decrease since 7:00 on July 6)	—
	Water level of Turbine Building	O.P.+ 2,825 mm (8 mm increase since 7:00 on July 6)	O.P.+ 3,162 mm (3 mm decrease since 7:00 on July 6)	O.P.+ 3,239 mm (9 mm decrease since 7:00 on July 6)	O.P.+ 3,207 mm (11 mm increase since 7:00 on July 6)
	Water level of Reactor Building	O.P.+ 4,452 mm (11 mm increase since 7:00 on July 6)	O.P.+ 3,378 mm (6 mm decrease since 7:00 on July 6)	O.P.+ 3,366 mm (1 mm decrease since 7:00 on July 6)	O.P.+ 3,213 mm (11 mm increase since 7:00 on July 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,871 mm (Increase from initial level:5,088 mm, 6 mm increase since 7:00 on July 6) O.P.+ 3,027 mm (Increase from initial level:3,753 mm, 4 mm increase since 7:00 on July 6) O.P.+ 4,389 mm (Water level from floor:593 mm, 4 mm increase since 7:00 on July 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:11 on July 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:06 on July 6)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:00 on July 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.