

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 9)**

Water Level of the accumulated water (at 7:00 on July 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,279 mm (11 mm increase since 16:00 on July 8)	O.P.+ 3,394 mm (9 mm increase since 16:00 on July 8)	—
	Water level of Turbine Building	O.P.+ 2,963 mm (32 mm increase since 16:00 on July 8)	O.P.+ 3,209 mm (10 mm increase since 16:00 on July 8)	O.P.+ 3,296 mm (2 mm increase since 16:00 on July 8)	O.P.+ 3,279 mm (9 mm increase since 16:00 on July 8)
	Water level of Reactor Building	O.P.+ 5,003 mm (35 mm increase since 16:00 on July 8)	O.P.+ 3,424 mm (10 mm increase since 16:00 on July 8)	O.P.+ 3,412 mm (2 mm decrease since 16:00 on July 8)	O.P.+ 3,282 mm (10 mm increase since 16:00 on July 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,903 mm (Increase from initial level:5,120 mm, 6 mm increase since 16:00 on July 8) O.P.+ 3,512 mm (Increase from initial level:4,238 mm, 122 mm increase since 16:00 on July 8) O.P.+ 4,419 mm (Water level from floor:623 mm, 7 mm increase since 16:00 on July 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:11 on July 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:06 on July 6)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:00 on July 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.