

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on July 9)**

Water Level of the accumulated water (at 16:00 on July 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,286 mm (7 mm increase since 7:00 on July 9)	O.P.+ 3,395 mm (1 mm increase since 7:00 on July 9)	—
	Water level of Turbine Building	O.P.+ 2,980 mm (17 mm increase since 7:00 on July 9)	O.P.+ 3,213 mm (4 mm increase since 7:00 on July 9)	O.P.+ 3,296 mm (No change since 7:00 on July 9)	O.P.+ 3,283 mm (4 mm increase since 7:00 on July 9)
	Water level of Reactor Building	O.P.+ 4,980 mm (23 mm decrease since 7:00 on July 9)	O.P.+ 3,430 mm (6 mm increase since 7:00 on July 9)	O.P.+ 3,417 mm (5 mm increase since 7:00 on July 9)	O.P.+ 3,284 mm (2 mm increase since 7:00 on July 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,969 mm (Increase from initial level:5,186 mm, 66 mm increase since 7:00 on July 9) O.P.+ 3,452 mm (Increase from initial level:4,178 mm, 60 mm decrease since 7:00 on July 9) O.P.+ 4,423 mm (Water level from floor:627 mm, 4 mm increase since 7:00 on July 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:11 on July 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:58 on July 9)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:00 on July 4   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	From 10:06AM, July 6 to 9:42AM, July 9, we transferred accumulated water from Unit 3 Turbine Building basement to the Central Radioactive Waste Treatment Facility (Miscellaneous Solid Waste Volume Reduction Treatment Building [High Temperature Incinerator Building]).				

For quick publication of the data of water level, values are provided as reference values.