

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 10)**

Water Level of the accumulated water (at 7:00 on July 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,293 mm (7 mm increase since 16:00 on July 9)	O.P.+ 3,396 mm (1 mm increase since 16:00 on July 9)	—
	Water level of Turbine Building	O.P.+ 3,009 mm (29 mm increase since 16:00 on July 9)	O.P.+ 3,221 mm (8 mm increase since 16:00 on July 9)	O.P.+ 3,294 mm (2 mm decrease since 16:00 on July 9)	O.P.+ 3,284 mm (1 mm increase since 16:00 on July 9)
	Water level of Reactor Building	O.P.+ 4,977 mm (3 mm decrease since 16:00 on July 9)	O.P.+ 3,438 mm (8 mm increase since 16:00 on July 9)	O.P.+ 3,415 mm (2 mm decrease since 16:00 on July 9)	O.P.+ 3,286 mm (2 mm increase since 16:00 on July 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,129 mm (Increase from initial level:5,346 mm, 160 mm increase since 16:00 on July 9) O.P.+ 3,243 mm (Increase from initial level:3,969 mm, 209 mm decrease since 16:00 on July 9) O.P.+ 4,429 mm (Water level from floor:633 mm, 6 mm increase since 16:00 on July 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:11 on July 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:58 on July 9)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:00 on July 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.