

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on July 10)**

Water Level of the accumulated water (at 16:00 on July 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,297 mm (4 mm increase since 7:00 on July 10)	O.P.+ 3,394 mm (2 mm decrease since 7:00 on July 10)	—
	Water level of Turbine Building	O.P.+ 3,027 mm (18 mm increase since 7:00 on July 10)	O.P.+ 3,224 mm (3 mm increase since 7:00 on July 10)	O.P.+ 3,293 mm (1 mm decrease since 7:00 on July 10)	O.P.+ 3,282 mm (2 mm decrease since 7:00 on July 10)
	Water level of Reactor Building	O.P.+ 4,936 mm (41 mm decrease since 7:00 on July 10)	O.P.+ 3,443 mm (5 mm increase since 7:00 on July 10)	O.P.+ 3,413 mm (2 mm decrease since 7:00 on July 10)	O.P.+ 3,285 mm (1 mm decrease since 7:00 on July 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,230 mm (Increase from initial level:5,447 mm, 101 mm increase since 7:00 on July 10) O.P.+ 3,127 mm (Increase from initial level:3,853 mm, 116 mm decrease since 7:00 on July 10) O.P.+ 4,433 mm (Water level from floor:637 mm, 4 mm increase since 7:00 on July 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:11 on July 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:58 on July 9)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:00 on July 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.