

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 11)**

Water Level of the accumulated water (at 7:00 on July 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,302 mm (5 mm increase since 16:00 on July 10)	O.P.+ 3,390 mm (4 mm decrease since 16:00 on July 10)	—
	Water level of Turbine Building	O.P.+ 3,057 mm (30 mm increase since 16:00 on July 10)	O.P.+ 3,229 mm (5 mm increase since 16:00 on July 10)	O.P.+ 3,288 mm (5 mm decrease since 16:00 on July 10)	O.P.+ 3,279 mm (3 mm decrease since 16:00 on July 10)
	Water level of Reactor Building	O.P.+ 4,956 mm (20 mm increase since 16:00 on July 10)	O.P.+ 3,448 mm (5 mm increase since 16:00 on July 10)	O.P.+ 3,409 mm (4 mm decrease since 16:00 on July 10)	O.P.+ 3,281 mm (4 mm decrease since 16:00 on July 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,402 mm (Increase from initial level:5,619 mm, 172 mm increase since 16:00 on July 10) O.P.+ 2,929 mm (Increase from initial level:3,655 mm, 198 mm decrease since 16:00 on July 10) O.P.+ 4,437 mm (Water level from floor:641 mm, 4 mm increase since 16:00 on July 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:11 on July 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:58 on July 9)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:33 on July 11 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	-At 8:33 AM on July 11, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for filter cleaning.				

For quick publication of the data of water level, values are provided as reference values.