

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on July 11)**

Water Level of the accumulated water (at 16:00 on July 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,306 mm (4 mm increase since 7:00 on July 11)	O.P.+ 3,391 mm (1 mm increase since 7:00 on July 11)	—
	Water level of Turbine Building	O.P.+ 3,073 mm (16 mm increase since 7:00 on July 11)	O.P.+ 3,231 mm (2 mm increase since 7:00 on July 11)	O.P.+ 3,286 mm (2 mm decrease since 7:00 on July 11)	O.P.+ 3,277 mm (2 mm decrease since 7:00 on July 11)
	Water level of Reactor Building	O.P.+ 4,903 mm (53 mm decrease since 7:00 on July 11)	O.P.+ 3,452 mm (4 mm increase since 7:00 on July 11)	O.P.+ 3,407 mm (2 mm decrease since 7:00 on July 11)	O.P.+ 3,280 mm (1 mm decrease since 7:00 on July 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,440 mm (Increase from initial level:5,657 mm, 38 mm increase since 7:00 on July 11) O.P.+ 3,258 mm (Increase from initial level:3,984 mm, 329 mm increase since 7:00 on July 11) O.P.+ 4,437 mm (Water level from floor:641 mm, 4 mm increase since 7:00 on July 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:11 on July 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:12 on July 11)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:17 on July 11 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	· From 9:58AM, July 9 to 10:00AM, July 11, we transferred accumulated water from Unit 3 Turbine Building basement to the Central Radioactive Waste Treatment Facility (Miscellaneous Solid Waste Volume Reduction Treatment Building [High Temperature Incinerator Building]). · The operation of 2nd Cesium Adsorption Apparatus (Sarry) was stopped at 8:33 AM, July 11, to clean the filter. At 2:17 PM, operation was started since the cleaning has completed.				

For quick publication of the data of water level, values are provided as reference values.