

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 13)**

Water Level of the accumulated water (at 7:00 on July 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,328 mm (1 mm decrease since 16:00 on July 12)	O.P.+ 3,390 mm (2 mm decrease since 16:00 on July 12)	—
	Water level of Turbine Building	O.P.+ 3,136 mm (24 mm increase since 16:00 on July 12)	O.P.+ 3,252 mm (1 mm decrease since 16:00 on July 12)	O.P.+ 3,287 mm (7 mm decrease since 16:00 on July 12)	O.P.+ 3,275 mm (3 mm decrease since 16:00 on July 12)
	Water level of Reactor Building	O.P.+ 4,796 mm (27 mm decrease since 16:00 on July 12)	O.P.+ 3,476 mm (2 mm increase since 16:00 on July 12)	O.P.+ 3,405 mm (2 mm decrease since 16:00 on July 12)	O.P.+ 3,278 mm (1 mm decrease since 16:00 on July 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,453 mm (Increase from initial level:5,670 mm, 6 mm increase since 16:00 on July 12) O.P.+ 3,343 mm (Increase from initial level:4,069 mm, 129 mm increase since 16:00 on July 12) O.P.+ 4,442 mm (Water level from floor:646 mm, 2 mm increase since 16:00 on July 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:43 on July 12)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:31 on July 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:17 on July 11 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.